

CONTENTS

FOREWORD	7
INTRODUCTION	9
1 Scope	10
2 Normative references	10
3 Terms and definitions	12
4 Ratings	18
4.1 Rated highest voltage for equipment (U_m)	18
4.2 Rated current (I_r)	18
4.3 Rated thermal short-time current (I_{th})	18
4.4 Rated dynamic current (I_d)	19
4.5 Minimum withstand values of cantilever load	19
4.6 Angle of mounting	20
4.7 Minimum nominal creepage distance	20
4.8 Temperature limits and temperature rise	20
4.9 Insulation levels	20
4.10 Test tap on transformer bushings	23
5 Operating conditions	23
5.1 Temporary overvoltages	23
5.2 Altitude	24
5.3 Temperature of ambient air and immersion media	25
5.4 Seismic conditions	25
5.5 Very fast transients (VFT)	26
5.6 Transformer insulating liquid	26
6 Ordering information and markings	26
6.1 Enumeration of characteristics	26
6.1.1 General	26
6.1.2 Application	26
6.1.3 Classification of bushings	26
6.1.4 Ratings	26
6.1.5 Operating conditions	27
6.1.6 Design	27
6.2 Markings	28
7 Test requirements	29
7.1 General requirements	29
7.2 Test classification	30
7.2.1 General	30
7.2.2 Type tests	30
7.2.3 Routine tests	31
7.2.4 Special tests	32
7.3 Condition of bushings during dielectric and thermal tests	32
8 Type tests	34
8.1 General	34
8.2 Dry or wet power-frequency voltage withstand test	34
8.2.1 Applicability	34
8.2.2 Test method and requirements	34

8.2.3	Acceptance.....	34
8.3	Long duration power-frequency voltage withstand test (ACLD).....	34
8.3.1	Applicability	34
8.3.2	Test method and requirements	34
8.3.3	Acceptance.....	35
8.4	Dry lightning impulse voltage withstand test.....	35
8.4.1	Applicability	35
8.4.2	Test method and requirements	35
8.4.3	Acceptance.....	36
8.5	Dry or wet switching impulse voltage withstand test	36
8.5.1	Applicability	36
8.5.2	Test method and requirements	36
8.5.3	Acceptance.....	37
8.6	Thermal stability test.....	37
8.6.1	Applicability	37
8.6.2	Test method and requirements	38
8.6.3	Acceptance.....	38
8.7	Electromagnetic compatibility tests (EMC)	38
8.7.1	Emission test.....	38
8.7.2	Immunity test.....	40
8.8	Temperature rise test.....	40
8.8.1	Applicability	40
8.8.2	Test method and requirements	40
8.8.3	Acceptance.....	41
8.9	Verification of thermal short-time current withstand.....	41
8.9.1	Applicability	41
8.9.2	Verification method and requirements.....	41
8.9.3	Acceptance.....	42
8.10	Cantilever load withstand test	42
8.10.1	Applicability	42
8.10.2	Test method and requirements	42
8.10.3	Acceptance.....	43
8.11	Tightness test on liquid-filled, compound-filled and liquid-insulated bushings.....	43
8.11.1	Applicability	43
8.11.2	Test method and requirements	43
8.11.3	Acceptance.....	44
8.12	Internal pressure test on gas-filled, gas-insulated and gas-impregnated bushings.....	44
8.12.1	Applicability	44
8.12.2	Test method and requirements	44
8.12.3	Acceptance.....	44
8.13	External pressure test on partly or completely gas-immersed bushings.....	44
8.13.1	Applicability	44
8.13.2	Test method and requirements	44
8.13.3	Acceptance.....	44
8.14	Verification of dimensions	44
8.14.1	Applicability	44
8.14.2	Acceptance.....	45
9	Routine tests	45

9.1	General.....	45
9.2	Measurement of dielectric dissipation factor ($\tan \delta$) and capacitance at ambient temperature	45
9.2.1	Applicability	45
9.2.2	Test method and requirements	45
9.2.3	Acceptance.....	45
9.3	Dry lightning impulse voltage withstand test.....	46
9.3.1	Applicability	46
9.3.2	Test method and requirements	46
9.3.3	Acceptance.....	46
9.4	Dry power-frequency voltage withstand test	46
9.4.1	Applicability	46
9.4.2	Test method and requirements	47
9.4.3	Acceptance.....	47
9.5	Measurement of partial discharge quantity	47
9.5.1	Applicability	47
9.5.2	Test method and requirements	47
9.5.3	Acceptance.....	47
9.6	Tests of tap insulation.....	48
9.6.1	Applicability and test requirements	48
9.6.2	Acceptance.....	48
9.7	Internal pressure test on gas-filled, gas-insulated and gas-impregnated bushings	49
9.7.1	Applicability	49
9.7.2	Test method and requirements	49
9.7.3	Acceptance.....	49
9.8	Tightness test on liquid-filled, compound-filled and liquid-insulated bushings.....	49
9.8.1	Applicability	49
9.8.2	Test method and requirements	49
9.8.3	Acceptance.....	49
9.9	Tightness test on gas-filled, gas-insulated and gas-impregnated bushings.....	49
9.9.1	Applicability	49
9.9.2	Test method and requirements	50
9.9.3	Acceptance.....	50
9.10	Tightness test at the flange or other fixing device	50
9.10.1	Applicability	50
9.10.2	Test method and requirements	50
9.10.3	Acceptance.....	51
9.11	Visual inspection and dimensional check	51
9.11.1	Applicability	51
9.11.2	Acceptance.....	51
10	Requirements and tests for non-capacitance graded bushings of rated highest voltages for equipment up to and including 52 kV	51
10.1	General.....	51
10.2	Temperature requirements	51
10.3	Level of immersion medium.....	51
10.4	Markings	51
10.5	Test requirements	52
10.5.1	General	52

10.5.2	Type tests	52
10.5.3	Routine tests	52
11	Recommendations for transport, storage, erection, operation and maintenance	53
11.1	General	53
11.2	Conditions during transport, storage and installation	53
11.3	Installation	53
11.4	Unpacking and lifting	53
11.5	Assembly	54
11.5.1	General	54
11.5.2	Mounting	54
11.5.3	Connections	54
11.5.4	Final installation inspection	54
11.6	Operation	55
11.7	Maintenance	55
11.7.1	General	55
11.7.2	Recommendation for the manufacturer	55
11.7.3	Recommendations for the user	56
11.7.4	Failure report	56
12	Safety	57
12.1	General	57
12.2	Electrical aspects	57
12.3	Mechanical aspects	57
12.4	Thermal aspects	58
13	Environmental aspects	58
Annex A (informative) Determination of the hottest spot in bushings with conductors embedded in the insulation material		59
Bibliography		60
Figure 1 – Factor m on the co-ordination switching impulse withstand voltage		24
Figure 2 – Marking plate for bushings for rated highest voltage for equipment (U_m) greater than 100 kV		29
Figure 3 – Marking plate for bushings for rated highest voltage for equipment (U_m) equal to or less than 100 kV, except for bushings for which Figure 4 is applicable		29
Figure 4 – Marking plate for bushings for rated highest voltage for equipment (U_m) equal to or less than 52 kV made of ceramic, glass or inorganic materials, resin or combined insulation (see 10.3)		29
Figure 5 – Voltage profile for long duration test		35
Table 1 – Minimum values of cantilever withstand load (see 4.5 and 8.10)		19
Table 2 – Maximum values of temperature and temperature rise above ambient air (see 4.8)		21
Table 3 – Insulation levels for highest voltage for equipment (U_m) (see 4.9, 8.2, 8.4, 8.5, 9.3 and 9.4)		22
Table 4 – Temperature of ambient air and immersion media		25
Table 5 – Applicability of type tests (see 7.2.2, excluding bushings according to Clause 10)		31
Table 6 – Applicability of routine tests (see 7.2.3, excluding bushings according to Clause 10)		32

Table 7 – Correction of test voltages (see 7.3)	33
Table 8 – Maximum values of $\tan \delta$ and $\tan \delta$ increase (see 9.2)	46
Table 9 – Maximum values of partial discharge quantity (see 8.3 and 9.5)	48
Table 10 – Applicability of type tests for bushings according to Clause 10 (see 10.5.1).....	52
Table 11 – Applicability of routine tests for bushings according to Clause 10 (see 10.5.3)	53