

## CONTENTS

FOREWORD.....	9
1 Scope .....	11
2 Normative references .....	11
3 Terms and definitions .....	12
4 General principles for the application of surge arresters .....	21
5 Surge arrester fundamentals and applications issues .....	22
5.1 Evolution of surge protection equipment .....	22
5.2 Different types and designs and their electrical and mechanical characteristics .....	23
5.2.1 General .....	23
5.2.2 Metal-oxide arresters without gaps according to IEC 60099-4 .....	24
5.2.3 Metal-oxide surge arresters with internal series gaps according to IEC 60099-6 .....	34
5.2.4 Externally gapped line arresters (EGLA) according to IEC 60099-8 .....	36
5.2.5 Application considerations .....	39
6 Insulation coordination and surge arrester applications .....	52
6.1 General.....	52
6.2 Insulation coordination overview .....	52
6.2.1 General .....	52
6.2.2 IEC insulation coordination procedure .....	53
6.2.3 Overvoltages .....	53
6.2.4 Line insulation coordination: Arrester Application Practices .....	59
6.2.5 Substation insulation coordination: Arrester application practices .....	64
6.2.6 Insulation coordination studies .....	68
6.3 Selection of arresters .....	70
6.3.1 General .....	70
6.3.2 General procedure for the selection of surge arresters .....	70
6.3.3 Selection of line surge arresters, LSA .....	84
6.3.4 Selection of arresters for cable protection .....	93
6.3.5 Selection of arresters for distribution systems – special attention .....	95
6.3.6 Application and coordination of disconnectors .....	96
6.3.7 Selection of UHV arresters .....	98
6.4 Standard and special service conditions .....	99
6.4.1 Standard service conditions .....	99
6.4.2 Special service conditions .....	99
7 Surge arresters for special applications .....	103
7.1 Surge arresters for transformer neutrals .....	103
7.1.1 General .....	103
7.1.2 Surge arresters for fully insulated transformer neutrals .....	103
7.1.3 Surge arresters for neutrals of transformers with non-uniform insulation .....	103
7.2 Surge arresters between phases .....	104
7.2.1 General .....	104
7.2.2 6-arrester arrangement .....	104
7.2.3 4-arrester (Neptune) arrangement .....	104
7.3 Surge arresters for rotating machines .....	105
7.4 Surge arresters in parallel .....	106

7.4.1	General .....	106
7.4.2	Combining different designs of arresters .....	107
7.5	Surge arresters for capacitor switching .....	107
7.6	Surge arresters for series capacitor banks .....	109
8	Asset management of surge arresters .....	110
8.1	General .....	110
8.2	Managing surge arresters in a power grid .....	110
8.2.1	Asset database .....	110
8.2.2	Technical specifications .....	110
8.2.3	Strategic spares .....	110
8.2.4	Transportation and storage .....	111
8.2.5	Commissioning .....	111
8.3	Maintenance .....	111
8.3.1	General .....	111
8.3.2	Polluted arrester housing .....	112
8.3.3	Coating of arrester housings .....	112
8.3.4	Inspection of disconnectors on surge arresters .....	112
8.3.5	Line surge arresters .....	112
8.4	Performance and diagnostic tools .....	112
8.5	End of life .....	113
8.5.1	General .....	113
8.5.2	GIS arresters .....	113
8.6	Disposal and recycling .....	113
Annex A (informative)	Determination of temporary overvoltages due to earth faults .....	114
Annex B (informative)	Current practice .....	118
Annex C (informative)	Arrester modelling techniques for studies involving insulation coordination and energy requirements .....	119
C.1	Arrester models for impulse simulations .....	119
C.2	Application to insulation coordination studies .....	120
C.3	Summary of proposed arrester models to be used for impulse applications .....	120
Annex D (informative)	Diagnostic indicators of metal-oxide surge arresters in service .....	122
D.1	General .....	122
D.1.1	Overview .....	122
D.1.2	Fault indicators .....	122
D.1.3	Disconnectors .....	122
D.1.4	Surge counters .....	122
D.1.5	Monitoring spark gaps .....	123
D.1.6	Temperature measurements .....	123
D.1.7	Leakage current measurements of gapless metal-oxide arresters .....	123
D.2	Measurement of the total leakage current .....	128
D.3	Measurement of the resistive leakage current or the power loss .....	129
D.3.1	General .....	129
D.3.2	Method A1 – Using the applied voltage signal as a reference .....	129
D.3.3	Method A2 – Compensating the capacitive component using a voltage signal .....	130
D.3.4	Method A3 – Compensating the capacitive component without using a voltage signal .....	131
D.3.5	Method A4 – Capacitive compensation by combining the leakage current of the three phases .....	131

D.3.6	Method B1 – Third order harmonic analysis .....	132
D.3.7	Method B2 – Third order harmonic analysis with compensation for harmonics in the voltage .....	133
D.3.8	Method B3 – First order harmonic analysis .....	133
D.3.9	Method C – Direct determination of the power losses .....	133
D.4	Leakage current information from the arrester manufacturer .....	133
D.5	Summary of diagnostic methods .....	135
Annex E (informative)	Typical data needed from arrester manufacturers for proper selection of surge arresters .....	136
Annex F (informative)	Typical maximum residual voltages for metal-oxide arresters without gaps according to IEC 60099-4 .....	137
Annex G (informative)	Steepness reduction of incoming surge with additional line terminal surge capacitance .....	138
G.1	General .....	138
G.2	Steepness reduction factor .....	138
G.3	Equivalent capacitance associated with incoming surge fronts .....	140
G.3.1	General .....	140
G.3.2	Examples of incoming surge steepness change, $f_s$ , using typical 550 kV & 245 kV circuit parameters .....	141
G.3.3	Change in coordination withstand voltage, $U_{cw}$ , with steepness reduction, $f_s$ .....	142
G.4	EMTP & capacitor charging models for steepness change comparisons at line open terminal .....	142
G.5	Typical steepness ( $S_0 = 1000 \text{ kV}/\mu\text{s}$ ), change comparisons with $C_0$ & $C_s$ .....	143
G.6	Faster steepness (2000 $\text{kV}/\mu\text{s}$ ), change comparisons with $C_0$ & $C_s$ .....	145
Annex H (informative)	Comparison of the former energy classification system based on line discharge classes and the present classification system based on thermal energy ratings for operating duty tests and repetitive charge transfer ratings for repetitive single event energies .....	147
H.1	General .....	147
H.2	Examples .....	150
Annex I (informative)	Estimation of arrester cumulative charges and energies during line switching .....	155
I.1	Simplified method of estimating arrester line switching energies .....	155
I.1.1	Introduction .....	155
I.1.2	Simplified method calculation steps .....	156
I.1.3	Typical line surge impedances with bundled conductors .....	158
I.1.4	Prospective switching surge overvoltages .....	158
I.1.5	Use of IEC 60099-4:2009 to obtain values for surge impedance and prospective surge voltages .....	159
I.2	Example of charge and energy calculated using line discharge parameters .....	160
I.3	Arrester line switching energy examples .....	164
I.3.1	General .....	164
I.3.2	Case 1 – 145 kV .....	167
I.3.3	Case 2 – 242 kV .....	167
I.3.4	Case 3 – 362 kV .....	167
I.3.5	Case 4 – 420 kV .....	168
I.3.6	Case 5 – 550 kV .....	168
Annex J (informative)	End of life and replacement of old gapped SiC-arresters .....	180
J.1	Overview .....	180
J.2	Design and operation of SiC-arresters .....	180

J.3 Failure causes and aging phenomena .....	180
J.3.1 General .....	180
J.3.2 Sealing problems .....	180
J.3.3 Equalization of internal and external pressure and atmosphere .....	181
J.3.4 Gap electrode erosion .....	181
J.3.5 Ageing of grading components .....	182
J.3.6 Changed system conditions .....	182
J.3.7 Increased pollution levels .....	182
J.4 Possibility to check the status of the arresters .....	182
J.5 Advantages of planning replacements ahead .....	182
J.5.1 General .....	182
J.5.2 Improved reliability .....	183
J.5.3 Cost advantages .....	183
J.5.4 Increased safety requirements .....	183
J.6 Replacement issues .....	183
J.6.1 General .....	183
J.6.2 Establishing replacement priority .....	183
J.6.3 Selection of MO arresters for replacement installations .....	184
Bibliography .....	185

Figure 1 – Example of GIS arresters of three mechanical/one electrical column (middle) and one column (left) design and current path of the three mechanical/one electrical column design (right) .....	29
Figure 2 – Typical deadfront arrester .....	30
Figure 3 – Internally gapped metal-oxide surge arrester designs .....	35
Figure 4 – Components of an EGLA acc. to IEC 60099-8 .....	36
Figure 5 – Typical arrangement of a 420 kV arrester .....	41
Figure 6 – Examples of UHV and HV arresters with grading and corona rings .....	42
Figure 7 – Same type of arrester mounted on a pedestal (left), suspended from an earthed steel structure (middle) or suspended from a line conductor (right) .....	43
Figure 8 – Installations without earth-mat (distribution systems) .....	44
Figure 9 – Installations with earth-mat (high-voltage substations) .....	45
Figure 10 – Definition of mechanical loads according to IEC 60099-4:2014 .....	47
Figure 11 – Distribution arrester with disconnector and insulating bracket .....	48
Figure 12 – Examples of good and poor connection principles for distribution arresters .....	50
Figure 13 – Typical voltages and duration example for differently earthed systems .....	54
Figure 14 – Typical phase-to-earth overvoltages encountered in power systems .....	55
Figure 15 – Arrester voltage-current characteristics .....	56
Figure 16 – Direct strike to a phase conductor with LSA .....	61
Figure 17 – Strike to a shield wire or tower with LSA .....	62
Figure 18 – Typical procedure for a surge arrester insulation coordination study .....	69
Figure 19 – Flow diagrams for standard selection of surge arrester .....	73
Figure 20 – Examples of arrester TOV capability .....	74
Figure 21 – Flow diagram for the selection of NGLA .....	87
Figure 22 – Flow diagram for the selection of EGLA .....	91
Figure 23 – Common neutral configurations .....	96

Figure 24 – Typical configurations for arresters connected phase-to-phase and phase-to-ground .....	105
Figure A.1 – Earth fault factor $k$ on a base of $X_0/X_1$ , for $R_1/X_1 = R_1 = 0$ .....	114
Figure A.2 – Relationship between $R_0/X_1$ and $X_0/X_1$ for constant values of earth fault factor $k$ where $R_1 = 0$ .....	115
Figure A.3 – Relationship between $R_0/X_1$ and $X_0/X_1$ for constant values of earth fault factor $k$ where $R_1 = 0,5 X_1$ .....	115
Figure A.4 – Relationship between $R_0/X_1$ and $X_0/X_1$ for constant values of earth fault factor $k$ where $R_1 = X_1$ .....	116
Figure A.5 – Relationship between $R_0/X_1$ and $X_0/X_1$ for constant values of earth fault factor $k$ where $R_1 = 2X_1$ .....	116
Figure C.1 – Schematic sketch of a typical arrester installation .....	119
Figure C.2 – Increase in residual voltage as function of virtual current front time .....	120
Figure C.3 – Arrester model for insulation coordination studies – fast- front overvoltages and preliminary calculation (Option 1) .....	121
Figure C.4 – Arrester model for insulation coordination studies – fast- front overvoltages and preliminary calculation (Option 2) .....	121
Figure C.5 – Arrester model for insulation coordination studies – slow-front overvoltages .....	121
Figure D.1 – Typical leakage current of a non-linear metal-oxide resistor in laboratory conditions .....	124
Figure D.2 – Typical leakage currents of arresters in service conditions .....	125
Figure D.3 – Typical voltage-current characteristics for non-linear metal-oxide resistors .....	126
Figure D.4 – Typical normalized voltage dependence at $+20^{\circ}\text{C}$ .....	126
Figure D.5 – Typical normalized temperature dependence at $U_C$ .....	127
Figure D.6 – Influence on total leakage current by increase in resistive leakage current .....	128
Figure D.7 – Measured voltage and leakage current and calculated resistive and capacitive currents ( $V = 6,3 \text{ kV r.m.s.}$ ) .....	130
Figure D.8 – Remaining current after compensation by capacitive current at $U_C$ .....	131
Figure D.9 – Error in the evaluation of the leakage current third harmonic for different phase angles of system voltage third harmonic, considering various capacitances and voltage-current characteristics of non-linear metal-oxide resistors .....	132
Figure D.10 – Typical information for conversion to "standard" operating voltage conditions .....	134
Figure D.11 – Typical information for conversion to "standard" ambient temperature conditions .....	134
Figure G.1 – Surge voltage waveforms at various distances from strike location (0,0 km) due to corona .....	139
Figure G.2 – Case 1: EMTP Model: Thevenin equivalent source, line ( $Z_c$ ) & substation bus ( $Z_c$ ) & Cap( $C_S$ ) .....	142
Figure G.3 – Case 2: Capacitor Voltage charge via line $Z$ : $u(t) = 2 \times U_{\text{surge}} \times (1 - \exp[-t/(Z \times C)])$ .....	143
Figure G.4 – EMTP model .....	143
Figure G.5 – Simulated surge voltages at the line-substation bus interface .....	144
Figure G.6 – Simulated Surge Voltages at the Transformer .....	145
Figure G.7 – EMTP model .....	145
Figure G.8 – Simulated surge voltages at the line-substation bus interface .....	146
Figure G.9 – Simulated surge voltages at the transformer .....	146

Figure H.1 – Specific energy in kJ per kV rating dependant on the ratio of switching impulse residual voltage ( $U_a$ ) to the r.m.s. value of the rated voltage $U_r$ of the arrester .....	148
Figure I.1 – Simple network used for Arrester Line Discharge Calculation and Testing according to IEC 60099-4:2009 .....	155
Figure I.2 – Linearized arrester equation in the typical line switching current range (voltage values shown are for a 372 kV rated arrester used on a 420 kV system) .....	156
Figure I.3 – Graphical illustration of linearized line switching condition and arrester characteristic .....	157
Figure I.4 – Range of 2 % slow-front overvoltages at the receiving end due to line energization and re-energization .....	159
Figure I.5 – Arrester class 2 & 3 voltages calculated by EMTP calculations: $U_{ps2}$ and $U_{ps3}$ ( $V \times 10^5$ ) .....	162
Figure I.6 – Class 2 & 3 arrester currents calculated by EMTP studies: $I_{ps2}$ and $I_{ps3}$ (A) .....	162
Figure I.7 – Arrester Class 2 & 3 cumulative charges calculated by EMTP simulation: $Q_{rs2}$ and $Q_{rs3}$ (C) .....	163
Figure I.8 – Arrester Class 2 & 3 cumulative absorbed energies calculated by EMTP simulation: $W_{s2}$ and $W_{s3}$ (kJ/kV $U_r$ ) .....	163
Figure I.9 – Typical Line Reclosing Computer Simulation Network .....	164
Figure I.10 – Typical 550 kV Reclose Switching Overvoltage Profile along 480 km Line .....	165
Figure I.11 – IEC LD based charge transfer, $Q_{rs}$ with varying arrester protective ratios .....	166
Figure I.12 – IEC LD based switching energy, $W_{th}$ with varying arrester protective ratios .....	166
Figure I.13 – $U_{ps}$ for 145 kV system simulation ( $V \times 10^5$ ) .....	170
Figure I.14 – $I_{ps}$ for 145 kV system simulation (A) .....	170
Figure I.15 – 1 Cumulative charge ( $Q_{rs}$ ) for 145 kV system simulation (C) .....	171
Figure I.16 – Cumulative energy ( $W_{th}$ ) for 145 kV system simulation (kJ/kV $U_r$ ) .....	171
Figure I.17 – $U_{ps}$ for 245 kV system simulation ( $V \times 10^5$ ) .....	172
Figure I.18 – $I_{ps}$ for 245 kV system simulation (A) .....	172
Figure I.19 – Cumulative charge ( $Q_{rs}$ ) for 245 kV system simulation (C) .....	173
Figure I.20 – Cumulative energy ( $W_{th}$ ) for 245 kV system simulation (kJ/kV $U_r$ ) .....	173
Figure I.21 – $U_{ps}$ for 362 kV system simulation ( $V \times 10^5$ ) .....	174
Figure I.22 – $I_{ps}$ for 362 kV system simulation (A) .....	174
Figure I.23 – Cumulative charge ( $Q_{rs}$ ) for 362 kV system simulation (C) .....	175
Figure I.24 – Cumulative energy ( $W_{th}$ ) for 362 kV system simulation (kJ/kV $U_r$ ) .....	175
Figure I.25 – $U_{ps}$ for 420 kV system simulation ( $V \times 10^5$ ) .....	176
Figure I.26 – $I_{ps}$ for 420 kV system simulation (A) .....	176
Figure I.27 – Cumulative charge ( $Q_{rs}$ ) for 420 kV system simulation (C) .....	177
Figure I.28 – Cumulative energy ( $W_{th}$ ) for 420 kV system simulation (kJ/kV $U_r$ ) .....	177
Figure I.29 – $U_{ps}$ for 550 kV system simulation ( $V \times 10^5$ ) .....	178
Figure I.30 – $I_{ps}$ for 550 kV system simulation (A) .....	178
Figure I.31 – Cumulative charge ( $Q_{rs}$ ) for 550 kV system simulation (C) .....	179
Figure I.32 – Cumulative energy ( $W_{th}$ ) for 550 kV system simulation (kJ/kV $U_r$ ) .....	179
Figure J.1 – Internal SiC-arrester stack .....	181
Table 1 – Minimum mechanical requirements (for porcelain-housed arresters) .....	46

Table 2 – Arrester classification .....	78
Table 3 – Definition of factor $A$ in formulas (14 and 15) for various overhead lines .....	82
Table 4 – Examples for protective zones calculated by formula (16) for open-air substations .....	83
Table 5 – Example of the condition for calculating lightning current duty of EGLA in 77 kV transmission lines .....	90
Table 6 – Probability of insulator flashover in Formula (18) .....	93
Table D.1 – Summary of diagnostic methods .....	135
Table D.2 – Properties of on-site leakage current measurement methods .....	135
Table E.1 – Arrester data needed for the selection of surge arresters .....	136
Table F.1 – Residual voltages for 20 000 A and 10 000 A arresters in per unit of rated voltage .....	137
Table F.2 – Residual voltages for 5 000 A, and 2 500 A arresters in per unit of rated voltage .....	137
Table G.1 – $C_S$ impact on steepness ratio $f_S$ and steepness $S_n$ .....	141
Table G.2 – Change in coordination withstand voltage, $U_{CW}$ .....	142
Table H.1 – Peak currents for switching impulse residual voltage test .....	147
Table H.2 – Parameters for the line discharge test on 20 000 A and 10 000 A arresters .....	148
Table H.3 – Comparison of the classification system according to IEC 60099-4:2009 and to IEC 6099-4 2014 .....	149
Table I.1 – Typical Arrester Switching ( $U_{ps}$ vs $I_{ps}$ ) Characteristics .....	156
Table I.2 – Typical line surge impedances ( $Z_S$ ) with single and bundled conductors .....	158
Table I.3 – Line Parameters Prescribed by IEC 60099-4:2009 Line Discharge Class Tests .....	159
Table I.4 – Line surge impedances and prospective surge voltages derived from line discharge tests parameters of IEC 60099-4:2009 for different system voltages and arrester ratings .....	160
Table I.5 – Comparison of energy and charge calculated by simplified method with values calculated by EMTP simulation – Base parameters from Table I.4, used for simplified method and for EMTP simulation .....	161
Table I.6 – Comparison of energy and charge calculated by simplified method with values calculated by EMTP simulation – Calculations using simplified method .....	161
Table I.7 – Comparison of energy and charge calculated by simplified method with values calculated by EMTP simulation – I.5.(c) Results from EMTP studies .....	161
Table I.8 – Results of calculations using the different methods described for different system voltages and arrester selection .....	169