

CONTENTS

FOREWORD	4
1 Scope	6
2 Normative references	6
3 Terms, definitions, symbols and units	7
3.1 Terms and definitions	7
3.2 Symbols and units	9
4 General	12
5 Rigid conductor arrangements	13
5.1 General	13
5.2 Calculation of electromagnetic forces	13
5.2.1 Calculation of peak force between the main conductors during a three-phase short-circuit	13
5.2.2 Calculation of peak force between the main conductors during a line-to-line short-circuit	13
5.2.3 Calculation of peak value of force between coplanar sub-conductors	14
5.3 Effective distance between main conductors and between sub-conductors	14
5.4 Calculation of stresses in rigid conductors	16
5.4.1 Calculation of stresses	16
5.4.2 Section modulus and factor q of main conductor composed of sub-conductors	17
5.4.3 Permitted conductor stress	20
5.5 Structure loads due to rigid conductors	21
5.6 Consideration of automatic reclosing	21
5.7 Calculation with special regard to conductor oscillation	22
5.7.1 General	22
5.7.2 Determination of relevant natural frequency	23
5.7.3 The factors V_F , $V_{\sigma m}$, $V_{\sigma s}$, V_{rm} and V_{rs}	23
6 Flexible conductor arrangements	26
6.1 General	26
6.2 Effects on horizontal main conductors	27
6.2.1 General	27
6.2.2 Characteristic dimensions and parameter	27
6.2.3 Tensile force $F_{t,d}$ during short-circuit caused by swing out (short-circuit tensile force) without dropper in midspan	30
6.2.4 Dynamic change of sag due to elongation of conductor and change of shape of the conductor curve	31
6.2.5 Tensile force $F_{t,d}$ during short-circuit caused by swing out (short-circuit tensile force) with dropper in the middle of the span	32
6.2.6 Tensile force $F_{f,d}$ after short-circuit caused by drop (drop force)	33
6.2.7 Horizontal span displacement b_h and minimum air clearance a_{min}	33
6.3 Effects on vertical main conductors (droppers)	34
6.4 Effects on bundled conductors	35
6.4.1 Characteristic dimensions and parameter	35
6.4.2 Tensile force $F_{pi,d}$ in the case of clashing sub-conductors	38
6.4.3 Tensile force $F_{pi,d}$ in the case of non-clashing sub-conductors	38
6.5 Structure loads due to flexible conductors	41
6.5.1 Design load for post insulators, their supports and connectors	41

6.5.2	Design load for structures, insulators and connectors with tensile forces transmitted by insulator chains.....	41
6.5.3	Design load for foundations	42
7	The thermal effect on bare conductors.....	42
7.1	General.....	42
7.2	Calculation of thermal equivalent short-circuit current	42
7.3	Calculation of temperature rise and rated short-time withstand current density for conductors	43
7.4	Calculation of thermal short-time strength for different durations of the short-circuit	44
Annex A (normative)	Equations for calculation of diagrams.....	46
Bibliography.....		51
Figure 1	– Factor k_{1s} for calculating the effective conductor distance.....	15
Figure 2	– Loading direction and bending axis for multiple conductor arrangements	18
Figure 3	– Factor e for the influence of connecting pieces in Equation (17)	24
Figure 4	– Factors V_F , $V_{\sigma m}$ and $V_{\sigma s}$ to be used with the three-phase and line-to-line short-circuits	25
Figure 5	– Factors V_{rm} and V_{rs} to be used with three-phase automatic reclosing	26
Figure 6	– Maximum swing out angle δ_{max} for a given maximum short-circuit duration T_{k1}	30
Figure 7	– Factor ψ for tensile force in flexible conductors	31
Figure 8	– Geometry of a dropper	33
Figure 9	– ν_2 as a function of ν_1	37
Figure 10	– $\nu_3 \cdot \sin \frac{180^\circ}{n}$ as a function of a_s/d	37
Figure 11	– ξ as a function of j and ε_{st}	38
Figure 12	– η as a function of j and ε_{st}	41
Figure 13	– Relation between rated short-circuit withstand current density ($T_{kr} = 1$ s) and conductor temperature	44
Table 1	– Effective distance a_s between sub-conductors for rectangular cross-section dimensions	16
Table 2	– Maximum possible values of $V_{\sigma m}V_{rm}$, $V_{\sigma s}V_{rs}$, V_FV_{rm}	19
Table 3	– Factors α , β , γ for different busbar support arrangements.....	20
Table 4	– Factor q	22
Table 5	– Section moduli W_m of main conductors with two or more stiffening elements between two adjacent supports. The stiffening elements are black.....	22
Table 6	– Recommended highest temperatures for mechanically stressed conductors during a short-circuit	43