

Contents

Page

European foreword	7
1 Scope.....	8
2 Normative references	9
3 Terms and definitions	10
3.1 Electrical safety and hazards.....	10
3.2 Earthing and equipotential bonding	12
3.3 Return circuit.....	14
3.4 Electric traction power supply system	16
3.5 Contact line	17
3.6 Corrosion and corrosion protection	20
3.7 Current collection.....	20
3.8 Residual current devices	21
3.9 General terms.....	21
4 Contact line zone and current collector zone	24
4.1 Overhead contact line.....	24
4.2 Ground level conductor rail.....	27
4.3 Trolleybuses and road vehicles using an overhead contact line.....	27
4.4 Limitation of the zones.....	28
5 Protective provisions against direct contact	29
5.1 Preconditions	29
5.1.1 General	29
5.1.2 Design procedure	29
5.1.3 Electrical clearances.....	30
5.1.4 Standing surface.....	31
5.2 Protection by clearance	32
5.2.1 Calculation method for protection by clearance	32
5.2.2 Dimensions of clearances	33
5.2.3 Clearances for working persons.....	35
5.2.4 Warning signs.....	35
5.2.5 Minimum height of wires of an overhead contact line system above traffic areas	36
5.2.6 Clearances above standing surfaces on vehicles	36
5.2.7 Feeders above loading roads.....	36
5.2.8 Clearance between live parts of overhead contact line systems and trees and bushes	36
5.3 Protection by electrically protective obstacles	36
5.3.1 General	36
5.3.2 Common requirements for electrically protective obstacles.....	37
5.3.3 Methods for determining reach.....	38
5.3.4 Requirements for electrically protective obstacles	40
5.3.5 Specific requirements for electrically protective obstacles in restricted areas	46
5.3.6 Anti climbing provisions.....	47
5.4 Protection against direct contact with live parts mounted on vehicles	47
5.5 Protective provisions allowing working under live conditions	48
5.5.1 General	48
5.5.2 Overhead contact lines for railways beneath structures	49
5.5.3 Overhead contact lines for trolley busses and electric road vehicles beneath structures	49

5.6	Specific protective provisions against electric shock in ground level conductor rail systems	51
5.6.1	Location of conductor rail at platforms	51
5.6.2	Exceptions	51
5.6.3	Protection provisions in workshops and depots	51
5.6.4	Protective boarding for ground level conductor rails in restricted areas	52
5.6.5	Requirements for top contact ground level conductor rails in public areas	52
5.6.6	Requirements for top contact ground level conductor rails in restricted areas	52
5.7	Specific protective provisions against electric shock in systems in which the wheels of the vehicles are not used for return circuit	55
5.7.1	General	55
5.7.2	Railway systems	55
5.7.3	Trolleybus systems and systems for electric road vehicles	55
6	Protective provisions against indirect contact and non-galvanic coupling	56
6.1	General	56
6.2	Protective provisions for exposed-conductive-parts	56
6.2.1	AC railways	56
6.2.2	DC railways	57
6.2.3	Exceptions for low voltage electric traction power supply systems	57
6.2.4	Stays of non-conductive masts	58
6.3	Protective provisions for wholly or partly conductive structures in the overhead contact line zone or the current collector zone	58
6.3.1	Protective provisions by means of connection to the return circuit	58
6.3.2	Exceptions for small wholly and partly conductive parts	59
6.3.3	Exceptions for temporarily stored parts close to the rails	59
6.3.4	Protective provisions preventing contact between conductive parts and live parts	59
6.3.5	Protective provisions by means of bare conductive parts connected to the return circuit	60
6.3.6	Protective provisions by automatic disconnection of supply	60
6.4	Parts which can become hazardous due to inductive or capacitive coupling	60
7	Protective provisions for low voltage non-traction power supply systems	60
7.1	General	60
7.2	Protective provisions for electrical installations in the overhead contact line zone or the current collector zone	61
7.2.1	Equipment of protection Class I	61
7.2.2	Equipment of protection Class II	63
7.2.3	Cables	63
7.2.4	Low voltage connected equipment	63
7.3	Protective provisions for installations which are endangered by the traction power supply return circuit	63
7.3.1	Design of low voltage non-traction power supply	63
7.3.2	Low voltage power supply by a TT system on the railway side	64
7.3.3	Low voltage power supply by TN system	67
7.3.4	Low voltage power supply by IT system	69
7.3.5	Special provisions	71
8	Protective provisions where track systems, which are utilized for carrying traction return current, or/and overhead contact line systems pass through hazardous zones	74
8.1	General	74
8.2	Equipotential bonding	75
8.3	Parallel pipework	76

8.4	Insulating joints	76
8.5	Surge arrester	76
8.6	Overhead contact line of loading sidings	77
9	Limits for touch voltage and protective provisions against the danger of rail potential	77
9.1	General	77
9.1.1	Preconditions	77
9.1.2	Body voltage and touch voltage	77
9.1.3	Touch voltage at vehicles	77
9.1.4	Short-circuit duration	78
9.1.5	Voltage limits and time duration aspects	78
9.2	Touch voltage limits in AC railways	78
9.2.1	General	78
9.2.2	AC voltage limits for the safety of persons	79
9.3	Touch voltage limits in DC railways	82
9.3.1	General	82
9.3.2	DC voltage limits for the safety of persons	82
9.4	Access Control	85
10	Additional requirements	85
10.1	Traction substations and traction switching stations	85
10.2	Cables	85
10.2.1	General requirements	85
10.2.2	Cables in AC electric traction power supply systems	86
10.2.3	Cables in DC electric traction systems	86
10.3	Extended return circuit connections and earthing conductors	86
10.3.1	General requirements	86
10.3.2	Continuity of the extended return circuit	86
10.3.3	Cross bonding of the return circuit	87
10.3.4	Railway systems in which the traction current is confined within insulated conductors	87
10.4	Removing of decommissioned contact lines	87
10.5	Means of achieving safe isolation between sections	87
10.6	Lightning protection	87
Annex A (normative)	Clearances from standing surfaces for exceptional use on existing lines with restricted gauge	88
Annex B (informative)	Typical layouts of protective obstacles	90
B.1	General	90
B.2	Examples	92
Annex C (normative)	Warning sign	99
Annex D (informative)	Guiding values for rail potential gradient	100
D.1	AC railways	100
D.2	DC railways	101
Annex E (informative)	Effective touch voltage and body voltage with respect to the body current	102
E.1	Preconditions for the calculation	102
E.2	Impedances	102
E.3	Body current and related body voltage	105
Annex F (normative)	Measurement methods for effective touch voltages	108
Annex G (normative)	Use of voltage-limiting devices	109
G.1	General	109

G.2	Types.....	109
G.3	Technical requirements.....	109
	Bibliography.....	111

Figures

Figure 1	— Overhead contact line zone and current collector zone	26
Figure 2	— Overhead contact line zone and current collector zone for trolley bus systems and electric road vehicles using a bipolar contact line.....	28
Figure 3	— Design procedure to achieve protection against direct contact.....	30
Figure 4	— Manikin model to be used for the analysis of the arm's reach	32
Figure 5	— Minimum distances to accessible live parts from standing surfaces accessible to persons	34
Figure 6	— Application of taut string line method compared with manikin method.	39
Figure 7	— Minimum distance behind electrically protective obstacles with openings.....	42
Figure 8	— Example for a gap between a standing surface and an electrically protective obstacle, side view.....	44
Figure 9	— Effect of an electrically protective obstacle on arms reach of person including an object, top view	45
Figure 10	— Live parts below standing surfaces	46
Figure 11	— Method for the determination of clearances for live parts on the outside of vehicles	48
Figure 12	— Example of an insulated obstacle beneath a structure	49
Figure 13	— Example of an insulated electrically protective obstacle beneath a structure for an unearthed installation	50
Figure 14	— Example of an insulated electrically protective obstacle beneath a structure for a bipolar overhead contact line in which the negative contact wire is earthed or connected to the return circuit of a tramway system	51
Figure 15	— Public level crossing, private level crossing	52
Figure 16	— Trackside structures	53
Figure 17	— Track-side telephone mounted on a signal-post	53
Figure 18	— Authorized trackside walking route.....	54
Figure 19	— Railway controlled crossing (depots, goods yard, station crossing).....	54
Figure 20	— Protection Class I equipment installed outside the overhead contact line zone and the current collector zone.....	62
Figure 21	— Typical TT system for AC railways.....	65
Figure 22	— Typical TT system for DC railways.....	66
Figure 23	— Typical TN system for AC railways.....	68
Figure 24	— Typical TN system for DC railways.....	69
Figure 25	— Typical IT system for AC railways	70
Figure 26	— TN system for AC railways with interconnected earth system.	72
Figure 27	— TN system for AC railways with multiple supply points.	73
Figure 28	— Disposition of rail-to-rail cross bonds and track-to-track cross bonds (double-rail illustration) and connection of the contact line in case of the loading siding having a contact line.....	76
Figure 29	— Location of a surge arrester outside the overhead contact line zone of a loading siding if there is a possibility of flashovers of the insulating pieces through lightning strikes	76
Figure 30	— Design of return circuit, with regard to permissible effective touch voltage by checking the rail potential or the effective touch voltage.....	79
Figure A.1	— Alternative clearances for existing lines/networks.	89
Figure B.1	— Typical protective obstacles and obstacle combinations and their dimensions and properties	91

Figure B.2 — Inclined protective obstacle, total height 1,00 m, solid-wall	92
Figure B.3 — Solid-wall protective obstacle, total height 1,69 m (balustrade wall).....	93
Figure B.4 — Combined protective obstacle with an inclined part on the top of the main protective obstacle, total height 1,50 m.....	94
Figure B.5 — Combined protective obstacle with an inclined part (0,50 m width) on the standing surface level, total height 1,00 m.....	95
Figure B.6 — Combined protective obstacle with an inclined part (1,60 m width) on the standing surface level, total height 1,00 m.....	96
Figure B.7 — Combined protective obstacle with a total height of 1,80 m.....	97
Figure B.8 — Arrangement of three protective obstacles.....	98
Figure C.1 — Warning sign	99
Figure D.1 — Guidance values for the rail potential gradient measured at the mast in a right angle to the track of an AC railway.....	100
Figure E.1 — Equivalent circuit for the calculation of the permissible touch voltage	104

1 bles

Table 1 — Electrical clearances	31
Table 2 — Protection clearances.....	31
Table 3 — Minimum vertical height V of accessible live parts above standing surfaces for public areas	35
Table 4 — Minimum distance d_O between live parts and an electrically protective obstacle	43
Table 5 — Maximum dimensions for small wholly and partly conductive parts	59
Table 6 — Types of low voltage non-traction supplies	64
Table 7 — Maximum permissible body voltages $U_{b, \max}$ in AC electric traction power supply systems as a function of time duration	80
Table 8 — Maximum permissible effective touch voltages $U_{te, \max}$ in AC electric traction power supply systems as a function of time duration.....	81
Table 9 — Maximum permissible body voltages $U_{b, \max}$ in DC electric traction power supply systems as a function of time duration	83
Table 10 — Maximum permissible effective touch voltages $U_{te, \max}$ in DC electric traction power supply systems as a function of time duration.....	83
Table D.1 — Guidance values for the rail potential gradient (see Figure D.1).....	101
Table E.1 — Body impedance Z_b , body resistance R_b and body current I_b	103
Table E.2 — Example of the maximum permissible prospective touch voltage for AC railways for short-term conditions and $R_a = 1\,150\,\Omega$	105
Table E.3 — Body currents, body voltages and touch voltages as function of time duration in AC electric traction power supply systems.....	106
Table E.4 — Body currents, body voltages and touch voltages as function of time duration in DC electric traction power supply systems.....	107